



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Environmental Management  
OIL POLLUTION/UNDERGROUND STORAGE TANK PROGRAM  
291 Promenade Street  
Providence, R.I. 02908 - 5767

August 31, 1992

Piero Maggiacomo  
100 Bosworth Street  
c/o Bosworth Associate  
Providence, RI

Re: 100 Bosworth Street  
Providence, RI LS--2836

Dear Mr. Maggiacomo:


This is in response to a request made by Triangle Engineering, dated 21 August 1992, for a variance from the underground storage tank closure requirements.

The following needs to be submitted before we will consider this variance request:

1. A signed closure application (attached) with the appropriate fee must be submitted to DEM/Office of Business Affairs/ 22 Hayes Street, Providence, RI.
2. A site plan, showing the location of the tank relative to other facilities considered to be impediments to removal. This plan should also indicate the direction of groundwater flow, and the location of referenced monitoring wells.
3. A proposed monitoring schedule for the monitoring wells, including the proposed analytical method for detecting contaminants in water and soil.
4. Further investigatory and remedial work shall be addressed in forthcoming Notice of Violation and Order.

Please contact me if you have any questions regarding this matter.

Sincerely,

A handwritten signature in cursive script, appearing to read "David Sheldon".

David Sheldon  
Senior Engineer

xc: J. Fester  
P. Sullivan  
M. DelRossi  
M. Cappelli